

Low-Emitting Materials

Certificate of Compliance

Awarded to: **THERMACOTE, INC. OF LAWRENCEVILLE, GA**
1369 HERRINGTON ROAD; ZIP CODE: 30044

Category: Construction Materials - Interior Paints & Coatings
Cert. Scheme: VOC Emissions

Accredited Compliance Designation: California Dept. of Public Health Standard Method v1.2 classroom & private office

*Conforms With LEED v4 ID+C, BD+C low-emitting interiors
Collaborative for High Performance Schools EQ 7.1.5 paints & coatings
Criteria of MAS Certified Green® Program low-emitting material
TVOC Emissions at 14-days 0.5 mg/m³ or less

Bracketed Products: ThermaCote®

Test Date 10/1/2018
& Report No.: 1801326

Certificate No.: MAS1801326a valid October 2018 to October 2019



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025
3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065
*outside of A2LA accreditation scope

